




TEST CERTIFICATE

SUMMARY OF TEST RESULTS

NUMBER	0405	DATE	06 /02 / 04
Client's data:	ETEM S.A. LIGHT METALS COMPANY 1, IROON POLYTEHNIU STR. GR 190 18 MAGOULA ATTIKIS GREECE		
Product description:	SINGLE SASH DOOR OPENING / TILTING		
Material:	ALUMINIUM		
System :	E - 40		



2150 x 1040 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 9A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

MARIANTHI CHATZIANTONIOU
TECHNICAL MANAGER

IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL