



BUILDING RESEARCH INSTITUTE (NISI) Ltd.

NOTIFIED TEST LABORATORY

Identification number NB 2032 of the Register of EC

Licence granted by the Ministry of Development and Public Works (MRRB), No CPD 10-2032


1618 Sofia, BULGARIA, 36 Nikola Petkov Blvd, tel.+359 2 856 10 82, fax +359 2 955 96 38, e-mail: nisi_sofia@abv.bg

TEST REPORT INITIAL TYPE TESTING

ITT-08.29 / 28.07.2008

The tests are carried out in compliance the Chapter Two of the Bulgarian *Regulation for the Essential Requirements to Constructions and Conformity Assessment of Construction Products (RERCCACP)* that bring into force the *Construction Products Directive (CPD) 89/106/EEC* of the Council of European Communities .

Product:	Installation bracket for ventilated facade system BRAVO – 07 bravo 01
Producer:	“STEELMET” AD, Sofia, 119 A Ilienci blvd.
Applicant:	“STEELMET” AD, Sofia, 119 A Ilienci blvd.
Document for assignment:	Contract No 60/2008
Essential requirements:	“1” – Mechanical resistance and stability
Test samples:	15 samples from installation brackets BRAVO – 07 bravo 01
Test period:	from 02.07.2008 to 25.07.2008
Conclusion:	The presented samples from installation brackets for ventilated facade system BRAVO – 07 bravo 01 meets the requirement of EN 845-1:2003 for ancillary components for masonry

Head of Testing Laboratory: 
Eng. Tzvetana. Giurova

Head of Institute: 
Dr. Eng. Rumén Guglev, assc. prof.



Testing data:

No	Characteristic	Unit of measurement	Test method	Test result	Requirement according to EN 845-1:2003 ¹⁾
1.	Bending strength at 2 mm deflection (photo 1) ²⁾	N	EN 845-10:2000	760	≥ 600
2.	Failure load at bending (photo 2) ²⁾	N	EN 845-10:2000	2330	≥ 2000
3.	Failure load at compression (photos 3 and 4) ²⁾	N	EN 845-10:2000	19620	≥ 15000
4.	Failure load at tension (photos 5 and 6) ²⁾	N	EN 845-10:2000	7150	≥ 5000

Note:

- 1) Declared value by the producer according to the requirements of EN 845-1:2003.
- 2) The photos taken during the test are given in an annex.

Technical documentation:

EN 845-1:2003 Specification for ancillary components for masonry - Part 1: Ties, tension straps, hangers and brackets

EN 845-10:2000 Methods of test for ancillary components for masonry - Part 10: Determination of load capacity and load deflection characteristics of brackets

Tests are carried out by

Eng. Emil Penev



Head of Testing Laboratory:

Eng. Izvetana Giurova

